




DATA SHEET							
MODEL	Length			VOLUME		WEIGHT	
	mm	inch	+/-	Liters	CU.Ft	Kg	LBS
11×35	891	35.08	4	46.7	1.65	4.95	10.89
11×44	1118	44.01	4	59.8	2.11	6.06	13.33

NOTES:

1. TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD,LATEST REVISION.
2. OPERATING SPECIFICATIONS:
 - A. MAXIMUM WORKING PRESSURE - 150PSI (10.5BAR)
 - B. TEMPERATURE RANGE - 34-122 °F (1-50 °C)
 - C. MAXIMUM VACUUM - 5.5"Hg (140mm Hg)
 - D. MEDIA - WATER
3. TEST REQUIREMENT
 - A. BURST PRESSURE TEST: 4.2MPa
 - B. CYCLIC PRESSURE TEST: 1.05MPa / 100,000 CYCLES
 - C. HYDROSTATIC PRESSURE TEST: 2.52MPa / KEEP 15MINs
4. VISUAL LINER INSPECTION
 - A. NO MORE THAN 10 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
 - B. NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 3 x 3mm
 - C. NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED
5. ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED
6. LABEL'S POSITION CAN BE CHANGED WITH THE CUSTOMER'S REQUIREMENT

								 CANATURE GROUP	
VERSION NO.	DESCRIPTION OF CHANGES:			SIGNATURE		DATE		11" FRP PRESSURE VESSEL	
DESIGNER			STANDARD	STAGE REMARK		NUMBER / SET		SCALE	
								1:4	MATERIAL: /
INSPECTION			AUTHORIZATION	PROJECTION				FRP-PV.11.00	
TECHNOLOGIST				TOTAL PAGES:		PAGE NO.			