






| MODEL  | Length |       |          | VOLUME |       | WEIGHT |        |
|--------|--------|-------|----------|--------|-------|--------|--------|
|        | mm     | inch  | +/- (mm) | Liters | CU.Ft | Kg     | LBS    |
| 24x72D | 2168   | 85.35 | 15       | 494    | 17.5  | 50     | 110.23 |
|        |        |       |          |        |       |        |        |



- NOTES:
- TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
  - OPERATING SPECIFICATIONS:
    - MAXIMUM WORKING PRESSURE - 150PSI (10.5BAR);
    - TEMPERATURE RANGE - 34-122 °F (1-50°C);
    - MAXIMUM VACUUM - 5.5"Hg (140mm Hg);
    - MEDIA - WATER
  - TEST REQUIRMENT
    - BURST PRESSURE TEST: 4.2MPa;
    - CYCLIC PRESSURE TEST: 1.05MPa / 100,000 CYCLES ;
    - HYDROSTATIC PRESSURE TEST: 2.52MPa / KEEP 15MINS ;
  - VISUAL LINER INSPECTION
    - NO MORE THAN 10 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS;
    - NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 3 x 3mm;
    - NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED;
  - ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED;
  - THE PERPENDICULARITY TOLERANCE OF THE AXIS OF THREADED INSERTS AND THE HORIZONTAL PLANE OF THE TANK IS <0.2mm;
  - THE PERPENDICULARITY TOLERANCE OF THE TANK BOBY AFTER BEING INSTALLED WITH BASE AND THE GROUND LEVEL IS<5mm;
  - LABEL'S POSITION CAN BE CHANGED WITH THE CUSTOMER'S REQUIREMENT.

|              |                         |                                                             |               |              |                                                                                       |          |                                                                                 |     |         |
|--------------|-------------------------|-------------------------------------------------------------|---------------|--------------|---------------------------------------------------------------------------------------|----------|---------------------------------------------------------------------------------|-----|---------|
|              |                         |                                                             |               |              |                                                                                       |          |                                                                                 |     |         |
| 5            | 07040031B               | The base (triangle) of the 24" tank                         |               |              |                                                                                       |          | 1                                                                               |     |         |
| 4            | 07032162                | PE inner pot of 24x72 tank, 4"-4" ( $\phi 607\times 1870$ ) |               |              | HDPE                                                                                  |          | 1                                                                               |     |         |
| 3            |                         | Composite material winding layer                            |               |              |                                                                                       |          | 1                                                                               |     |         |
| 2            |                         | Label                                                       |               |              |                                                                                       |          | 1                                                                               |     |         |
| 1            | 07080034                | UN threaded inserts (big) of 4" tank                        |               |              | PP0                                                                                   |          | 2                                                                               |     |         |
| No.          | Part No.                | Product Name                                                |               |              | Material                                                                              |          | Quantity                                                                        |     | Remarks |
|              |                         |                                                             |               |              |                                                                                       |          | <div>開能 CANATURE GROUP</div> <div>Canature</div> <div>2472 frp tank 4"-4"</div> |     |         |
|              |                         |                                                             |               |              |                                                                                       |          |                                                                                 |     |         |
|              |                         |                                                             |               |              |                                                                                       |          |                                                                                 |     |         |
| VERSION NO.  | DESCRIPTION OF CHANGES: |                                                             |               |              | SIGNATURE                                                                             | DATE     |                                                                                 |     |         |
| DESIGNER     |                         |                                                             | STANDARD      | STAGE REMARK | NUMBER /SET                                                                           | SCALE    | 07542472E                                                                       |     |         |
|              |                         |                                                             |               |              | 1                                                                                     | 1:10     | MATERIAL:                                                                       | --- |         |
| INSPECTION   |                         |                                                             | AUTHORIZATION | PROJECTION   |  |          | SOURCING FROM:                                                                  | zz  |         |
| TECHNOLOGIST |                         |                                                             |               | TOTAL PAGES: |                                                                                       | PAGE NO. | 2472 frp tank 4"-4"                                                             |     |         |