

Our recommendations

Name and reference	Recommendation
Injector seals kit Kj-34-E0-515 	Verification : Each year Replacement : Every 3 years
Piston plate kit Ka-40-D0-684 	Verification : Each year Replacement : Every 3 years
Interface seals kit (5 pcs) Kj-34-E0-519 	Verification : Each year Replacement : Every 3 years
2 1/2" Tank seal (10 pcs) Kj-34-E0-520 	Verification at each dismantling Replacement if damaged
Main and brine seals kit Ke-40-D0-665 	Verification : Each year Replacement : Every 3 years
O-ring tube seal Ø 25 mm (10 pcs) Kj-34-E0-521 O-ring tube seal Ø 27 mm (10 pcs) Kj-34-E0-569 	Verification at each dismantling Replacement if damaged
Inlet outlet seals kit (5 pcs) Kj-34-E0-518 	Verification : Each year Replacement : Every 5 years
LR 20 Alkaline batteries Ba-20-D0-535	Replacement frequency : • 1 regeneration per week : 3 years* • 3 regenerations per week: 2 years* • 1 regeneration per day : 1 year*
Lithium-ion battery Ba-20-D0-47	Replacement frequency : • 1 regeneration per week : 10 years* • 3 regenerations per week: 5 years* • 1 regeneration per day: 2 years*
Lu-00-L0-174	Use only Cappers silicone grease, other lubricants may damage plastic parts or may not comply with applicable regulations. The use of spray lubricant is prohibited.

*These values were noticed with Cappers' supplies and can be strongly reduced on other brands.